

DOI 10.31489/2022BMG4/164-172

UDC 613.31.34:614.777 (574.31)

S.B. Akhmetova*, I.A. Belyayev, A.O. Omarova, Zh.T. Amirkhanova

Karaganda Medical University, Karaganda, Kazakhstan

**Corresponding author: S.Ahmetova@qmu.kz*

The study of microbial contamination of water and sanitary facilities in the Karaganda regional clinical hospital during different seasons

In modern conditions, the quality of water supply and the state of water management facilities play a key role in maintaining the health of people and animals, as well as the life quality of the population. In this regard, we set the goal of our research to assess the level of microbial contamination of water and sanitary facilities in the Regional Clinical Hospital of Karaganda district as the central and most powerful medical institution in the region in different seasons of the year. Based on the results of our study, the following conclusions can be drawn: during the research period, seasonal variability of indicators in the studied samples of tap water can be traced. The water of the central water supply is characterized by systematic excesses of both total coliform and thermotolerant coliform bacteria. In the city of Karaganda, there is a great stability in the quality of water supply, regardless of the seasons, despite the excess of standard indicators. It can talk about either the low quality of water treatment, or about quality problems in the water supply network at the sampling points (Regional Clinical Hospital of Karaganda). At the same time, it is worth noting the high percentage (almost 98 %) of positive samples in the spring. In winter, there is a lower percentage of positive samples and a significantly lower microbial quantity. The quality of drinking water decreases in the spring, we believe that the most likely reason for the deterioration in the quality of drinking water is the ingress of melt water and rainwater into the source. Violations of the technological conditions for the operation of water treatment facilities, secondary water pollution in worn-out water distribution networks could also be the cause of unsatisfactory results. In the Regional Clinical Hospital of Karaganda, a higher percentage of positive swabs is noted, which is associated with a higher load on the regional hospital, as well as a better supply of antimicrobial disinfectants, which leads to selective selection of more resistant strains.

Keywords: tap water, microbiology, general coliform bacteria, thermotolerant coliform bacteria, swabbing.

Introduction

Drinking water is one of the main environmental factors that can have both a positive and a negative impact on the health of the population, and providing the population with high-quality drinking water is one of the most important factors in protecting health.

Water is one of the main factors in the spread of infectious diseases. The water way of transmission is typical for cholera, typhoid fever, dysentery, leptospirosis, tularemia, infectious hepatitis, adenovirus infections and helminthiases. The cause of morbidity in about 40 % of the population is microbiological contamination of water [1–3].

Drinking water transported through distribution networks will be subject to both chemical and microbiological quality changes. Contamination of drinking water, especially fecal contamination, is a major public health problem.

Exposure to unsafe drinking water can occur in domestic (home) and non-domestic settings, such as healthcare facilities (HCF) [4].

Sanitary and bacteriological control in medical facilities is the creation and maintenance of safe conditions for the treatment and diagnostic process for both patients and medical personnel. Safety is also important, especially in settings with vulnerable populations such as immunocompromised patients in healthcare settings [5].

According to the WHO, drinking water is water that does not pose a risk to health during the entire time it is consumed. The safety criterion is compliance with the requirements of state regulations [6].

The quality of water in water bodies, drinking water in centralized water supply systems is regulated by the requirements set forth in the sanitary rules: "Sanitary and epidemiological requirements for water sources, places of water intake for domestic and drinking purposes, domestic and drinking water supply and places of cultural and domestic water use and safety of water bodies" Order of the Minister of National Economy of the Republic of Kazakhstan dated March 16, 2015 No. 209. Registered with the Ministry of Justice of the Republic of Kazakhstan on April 22, 2015 No. 10774 [7].

Sanitary and bacteriological monitoring is an important criterion for surveillance in addressing water issues. Drinking water must comply with the regulated indicators for microbiological characteristics at all stages of water supply to the consumer [8–13]. Therefore, the actual task of water treatment in providing the population with drinking water is to guarantee its safety in terms of epidemics.

The purpose of our study is to assess the level of microbial contamination of water and sanitary facilities in the Regional Clinical Hospital of Karaganda district in different seasons of the year.

Experimental

In the regional clinical hospital of Karaganda in the spring-summer and autumn-winter periods, samples of tap water and swabs from environmental objects were taken in the following objects (Tab. 1).

Table 1

Number of water sampling and washings from environmental objects

Regional Clinical Hospital of Karaganda (therapeutic and surgical building).	
<i>Autumn-winter period</i>	<i>Spring-summer period</i>
22 water samples and 50 swabs from environmental objects.	25 water samples and 38 swabs from environmental objects.

Water sampling was carried out in accordance with the requirements of "Sanitary and epidemiological requirements for water sources, places of water intake for domestic and drinking purposes, domestic and drinking water supply and places of cultural and domestic water use and safety of water bodies", Order of the Minister of National Economy of the Republic of Kazakhstan dated March 16, 2015 Year No. 209. Registered with the Ministry of Justice of the Republic of Kazakhstan on April 22, 2015 No. 10774" [14, 15].

When taking samples of water from taps, they were first burned with a flame of a burning cotton swab moistened with alcohol, then they were completely opened and the water was drained for 10 minutes. Water was poured into sterile glass bottles (500 ml) in a sterile manner, without wetting the neck to prevent soaking of the cork.

All water samples and washings taken for the study were numbered, and the accompanying document was filled out. A cooler bag (Thermo-Kont MK, Russia) was used to transport the test samples. The studies were carried out on the day of selection [16, 17].

The selected water samples were examined for microbiological parameters: total microbial number, total coliform bacteria, thermotolerant coliform bacteria [18–22].

The membrane filtration method [23, 24] was used to study water; the method is modern, accurate, and provides quantitative and reproducible detection of contamination traces. The principle of the method is based on filtering a certain volume of water through a membrane that traps bacteria. The membrane is then incubated on an appropriate selective medium, which allows it to multiply and form colonies.

A single-funnel microbiological control system for membrane filtration manufactured by Sartorius was used in the work, using a filtration system for cellulose nitrate filters with a pore size of 0.45 μm and substrates with nutrient agar and Endo medium.

Sampling of swabs: sterile cotton swabs were moistened with 10 ml of sterile saline broth using a template to wipe the surface of the objects in the horizontal and vertical directions. After taking samples from the surface, swabs were immediately placed into test tubes with KODA transport medium [25–29].

Washouts from environmental objects and hands of personnel after a day of incubation in broth culture at a temperature of $36\pm 1^{\circ}\text{C}$ for 18–24 hours, subculture was carried out on solid nutrient media: Hi Media Salmonella — Shigellachrom Agar, yolk-salt agar, Endo medium.

Results and Discussion

As a result of microbiological inoculation of tap water samples, fluctuations in CFU/ml are observed according to the seasons of the year, which is associated with weather conditions. In the spring period, an increase in CFU/ml is observed, and in winter, a decrease in CFU/ml, the study results are shown in Tables 2, 3.

Table 2

The results of microbiological indicators of the quality of tap water in the regional clinical hospital of Karaganda (therapeutic and surgical building) in the autumn-winter period

№	Water sampling points	MAFAM / (CFU per 1ml)	GCB (CFU per 1ml)	TCB (CFU per 1ml)
		Norm for ND: no more than 50 CFU / ml	Norm according to ND: absence in 100 ml	Norm according to ND: absence in 100 ml
<i>Surgical building</i>				
1	General surgery Small procedural	3	11	0
2	Gynecology	1,6	52	8
3	Gynecology inventory	1,5	83	1
4	Proctology sanitary room	3	21	7
5	Purulent surgery, small procedural	2,3	4	2
6	Urology Small procedural № 1	3	7	6
7	Urology Small procedural № 2	3	7	6
8	Reception area shower	3	5	5
<i>Therapeutic building</i>				
9	Endocrinology treatment room	3	12	12
10	endocrinology service toilet	3	12	5
11	Endocrinology room	3	7	7
12	Nephrology treatment room	3	0	0
13	Nephrology toilet	2,5	50	4
14	Rheumatology toilet	1,6	20	54
15	Neurology inventory	2,4	10	30
16	Neurology procedural	2	5	40
17	Pulmonology inventory	2,5	25	25
18	Pulmonology procedural	2,6	26	24
19	Inventory room X-ray diagnostics	3	12	16
20	X-ray diagnostics treatment room	2,5	30	16
21	Ward № 1	2	3	4
22	Ward № 2	3	10	4

Table 3

Results of microbiological indicators of the quality of tap water in the regional clinical hospital of Karaganda (therapeutic and surgical building) in the spring and summer

№	Water sampling points	MAFAM / (CFU per 1ml)	GCB (CFU per 1ml)	TCB (CFU per 1ml)
		Norm for ND: no more than 50 CFU / ml	Norm according to ND: absence in 100 ml	Norm according to ND: absence in 100 ml
<i>Surgical Corps</i>				
1	Ward № 2	1	10	0
2	Dynamic Observation Chamber	2	4	2
3	endoscopy toilet	1	20	2

4	Gynecology emergency room	1	22	3
5	Urology	1	28	1
6	Proctology	2	1	0
7	Thoracic department purulent	1	12	0
8	ICU service toilet	1	7	0
9	General surgery sanitary block	1	30	1
10	Food preparation room gynecology	1	9	0
11	Small procedural gynecology	0	0	2
	<i>Therapeutic building</i>			
12	Inventory reception room	1	15	3
13	Toilet for visitors to the polyclinic	1	1	3
14	Rheumatology razdatka	1	1	2
15	Resident Endocrinology	4	12	0
16	Wc endocrinology	2	5	1
17	Inventory rheumatology	4	30	13
18	Rheumatology dispensing	1	6	4
19	Nephrology treatment room	1	1	0
20	Sanitary room left wing	1	15	0
21	Endocrinology inventory	1	0	0
22	Pulmonology razdatka	3	48	1
23	Inventory neurology	1	3	0
24	Food preparation room gastroenterology	1	14	2
25	Electrotherapy cabinet	1	1	0

In the spring-summer and autumn-winter periods in the studied water samples of the regional clinical hospital in Karaganda, the MAFAM indicators do not exceed the standard (Tables 2, 3).

The autumn-winter period, according to the results of GCB, TCB, indicates a significant level of microbial contamination in objects. According to the study, 21 samples did not meet the hygienic standards in terms of the presence of intestinal bacteria (GCB), in this table (Table 2) only one water sample (Nephrology — treatment room) corresponds to ND.

Total coliform bacteria (CFU per 100 ml) in 20 samples exceeded, in the sample (Inventory Gynecology) regional clinical hospital in Karaganda reached 83 CFU per 100 ml.

The autumn-winter period was positive in 95.4 % of samples for common coliform bacteria and the average titer was 19.6 CFU per 100 ml, for thermotolerant bacteria 90.9 % of samples, the average titer was 12.5 CFU per 100 ml.

Analysis of the microbial landscape of tap water at the points of sampling of the regional clinical hospital in Karaganda in the spring-summer period of observation showed an excess in terms of total coliform bacteria and TCB, which indicates an indicator of microbial contamination (Table 3).

In terms of total coliform bacteria, the amount less than >10 CFU/100 ml was found in samples No. 2 (Dynamic Observation Ward), No. 6 (Proctology), No. 8 (ICU service toilet), No. for visitors to the polyclinic), No. 14 (Rheumatology food preparation room), No. 16 (San. node endocrinology), No. 18 (Distributing rheumatology), No. 19 (Nephrology treatment room), No. 23 (Inventory neurology). The highest number of total coliform bacteria ranged from 10 to 48 cfu/100 ml.

When evaluating the results, TCB was found in samples No. 2, No. 3, No. 4, No. 5, No. 9, No. 11, No. 12, No. 13, No. 14, No. 16, No. 18, No. 22, No. 24, and their number was from 1 to 3 CFU/100 ml in the water sample.

Thus, the percentage of positive samples according to GCB was 92 %, and the average titer was 11.8 CFU per 100 ml. Thermotolerant coliform bacteria were positive in 56 % of samples, mean titer 2.8. The leading position in terms of the high indicator for the GCB of the test water sample was shown by a sample (distributed pulmonology) 48 CFU/ml, a sample (inventory rheumatology) by TCB 13 CFU/ml.

Thus, unsatisfactory sanitary and bacteriological indicators for GCB and TCB indicate unsanitary conditions and require measures to be taken to eliminate the unfavorable situation in the Regional Clinical Hospital of Karaganda, especially in the spring.

Results of swabs from environmental objects: In winter, conditionally pathogenic microorganisms were detected from the following washings of the Karaganda Regional Clinical Hospital: strains of *Pseudomonas aeruginosa* in the gynecological department from the tap and toilet bowl, *Acinetobacter baumannii* from the

toilet bowl in purulent surgery. The detection of typical nosocomial pathogens *Pseudomonas aeruginosa* and *Acinetobacter baumannii* in swabs is epidemiologically alarming and requires an objective assessment of the situation.

Results of washings from environmental objects: In winter, conditionally pathogenic microorganisms were detected from the following washings of the Karaganda Regional Clinical Hospital: strains of *Pseudomonas aeruginosa* in the gynecological department from the tap and toilet bowl, *Acinetobacter baumannii* from the toilet bowl in purulent surgery. The detection of typical nosocomial pathogens *Pseudomonas aeruginosa* and *Acinetobacter baumannii* in swabs is epidemiologically alarming and requires an objective assessment of the situation.

Thus, in the Regional Clinical Hospital of Karaganda, the presence of microorganisms characteristic of pathogens of nosocomial infections such as *S. aureus*, *Ps. aeruginosa*, *K. variicola* and *A. baumannii*. In large multidisciplinary hospitals, such as the regional clinical hospital, the formation of its own microbiocenosis of a multidisciplinary hospital is natural, but these pathogens are characterized by high risks of the formation of multi- and pan-resistant strains.

Conclusions

During the study period, seasonal variability of indicators in the studied samples of tap water is traced. The water of the central water supply is characterized by systematic excesses of both total coliform and thermotolerant coliform bacteria.

In the city of Karaganda, there is a great stability in the quality of water supply, regardless of the seasons, despite the excess of standard indicators. It can talk about either the low quality of water treatment or about quality problems in the water supply network at the sampling points (Regional Clinical Hospital of Karaganda). At the same time, it is worth noting the high percentage (almost 98 %) of positive samples in the spring. In winter, there are a lower percentage of positive samples and a significantly lower microbial load.

The quality of drinking water decreases in the spring, we believe that the most likely reason for the deterioration in the quality of drinking water is the ingress of melt water and rainwater into the source. Violations of the technological conditions for the operation of water treatment facilities, secondary water pollution in worn-out water distribution networks could also be the cause of unsatisfactory results.

In the Regional Clinical Hospital of Karaganda, a higher percentage of positive swabs is noted, which is associated with a higher load on the regional hospital, as well as a better supply of antimicrobial disinfectants, which leads to selective selection of more resistant strains.

Acknowledgements

This research was funded by the Science Committee of the Ministry of Education and Science of the Republic of Kazakhstan (Grant AP09058465).

References

- 1 Пособие по улучшению водоснабжения, санитарии и гигиены в медицинских учреждениях. — Женева: Всемирная организация здравоохранения, 2018. Лицензия: CC BY-NC-SA 3.0 IGO. [Электронный ресурс]. Режим доступа: <https://apps.who.int/iris/bitstream/handle/10665/273032/9789244511695-rus.pdf>.
- 2 Водоснабжение, санитария и гигиена в медицинских учреждениях: Практические шаги по обеспечению всеобщего доступа к качественной помощи. — Женева: Всемирная организация здравоохранения, 2019. Лицензия: CC BY-NC-SA 3.0 IGO [Электронный ресурс]. Режим доступа: https://www.unwater.org/app/uploads/2020/04/Water-sanitation-and-hygiene-in-health-care-facilities-Practical-steps-to-achieve-universal-access-for-quality-care_RU.pdf.
- 3 Водоснабжение, санитария и гигиена в учреждениях здравоохранения. Семьдесят вторая сессия Всемирной ассамблеи здравоохранения. 72.7 Пункт 12.5 Повестки дня 28 мая 2019 г. [Электронный ресурс]. Режим доступа: https://extranet.who.int/iris/restricted/bitstream/handle/10665/329293/A72_R7-ru.pdf?sequence=1&isAllowed=y.
- 4 Abebe L. Microbial contamination of non-household drinking water sources: a systematic review / L. Abebe, A.J. Karon, A.J. Koltun, R.D. Cronk, R. E.S. Bain, J. Bartram // Journal of Water, Sanitation and Hygiene for Development. — 2018. — Vol. 8 (3). — P. 374-385. <https://doi.org/10.2166/washdev.2018.080>.
- 5 Shields K.F. Association of supply type with fecal contamination of source water and household stored drinking water in developing countries: a bivariate meta-analysis / K.F. Shields, R.E.S. Bain, R. Cronk, J.A. Wright, J. Bartram // Environ. Health Perspect. — 2015. — Vol. 123 (12). — P. 1222-1231. <https://doi.org/10.1289/ehp.1409002>.
- 6 Целевые показатели к Протоколу по проблемам воды и здоровья Конвенции по охране и использованию трансграничных водотоков и международных озер (Республика Казахстан). — Астана, 2017. — 52 с.

- 7 Санитарно-эпидемиологические требования к водосточникам, местам водозабора для хозяйственно-питьевых целей, хозяйственно-питьевому водоснабжению и местам культурно-бытового водопользования и безопасности водных объектов. Приказ Министра национальной экономики Республики Казахстан от 16 марта 2015 года № 209 [Электронный ресурс]. Режим доступа: https://online.zakon.kz/Document/?doc_id=36325897.
- 8 Тогузбаева К.К. Гигиеническая оценка качества сельского водоснабжения по результатам лабораторных данных Енбекшиказахского района / К.К. Тогузбаева, А.Е. Джанбатырова, Л.Б. Сейдуанова, Л.С. Ниязбекова, А.У. Калдыбай, Д.Д. Жунистаев, А.С. Мейрман, Е.Т. Толей // Вестн. Казах. нац. мед. ун-та. — 2015. — № 2. — С. 634–637.
- 9 Тогузбаева К.К. Гигиеническая оценка влияния качества хозяйственно-питьевого водоснабжения на здоровье сельского населения Алматинской области / К.К. Тогузбаева, Ш.К. Мырзахметова, Л.С. Ниязбекова, Л.Ж. Оракбай, Д.Д. Жунистаев, Л.Б. Сейдуанова, А.К. Сайлыбекова, А.Б. Смагулов, К.А. Суменова, Г.Р. Сабирова // Вестн. Казах. нац. мед. ун-та. — 2015. — № 3(3). — С. 33–38.
- 10 Омарова М.Н. Состояние питьевого водоснабжения в сельской местности и его влияние на здоровье населения / М.Н. Омарова, Ж.С. Тотанов, Л.Ю. Черепанова, Л.К. Глубоковских, А.М. Еремеев, С.И. Жолдаспаев // Демографическая ситуация в Республике, проблемы и перспективы: материалы Респ. науч.-практ. конф. — Караганда, 2010. — С. 101, 102.
- 11 Нурбакыт А.Н. Оценка населением санитарно-гигиенических условий в медицинских организациях г. Алматы и Алматинской области [Электронный ресурс]. / А.Н. Нурбакыт, К.С. Абсатарова, Ж.К. Бурибаева, Г.Е. Казангапова, Е.Ж. Сарсенбаев, Б.Р. Давибаева. Режим доступа: http://www.rusnauka.com/28_OINXXI_2010/Medecine/72649.doc.htm.
- 12 Журавлева Т.А. Анализ финансирования здравоохранения в России и его оценка для сохранения здоровья нации / Т.А. Журавлева, Н.А. Гревцева // Финансовая жизнь. — 2016. — № 4. — С. 75–80.
- 13 Жаркинов Е.Ж. Современные проблемы гигиены села и задачи научных исследований / Е.Ж. Жаркинов, В.Н. Красников, Ж.С. Тотанов, К.К. Ташметов, Л.Ю. Черепанова // Медицина и экология. — 2002. — № 2 (22). — С. 27–29.
- 14 Руководство по обеспечению качества питьевой воды. — 4-е изд. [Электронный ресурс]. — Женева: Всемирная организация здравоохранения; 2017. Лицензия: CC BY-NC-SA 3.0 IGO. Режим доступа: https://apps.who.int/iris/bitstream/handle/10665/44584/9789241548151_eng.pdf?sequence=1.
- 15 Bekturganov Z. Water related health problems in Central Asia — A review / Z. Bekturganov, K. Tussupova, R. Berndtsson, N. Sharapatova, K. Arungazin, M. Zhanasova // Water. — 2016. — Vol. 8. — Article ID 219. <https://doi.org/10.3390/w8060219>.
- 16 Доклад о результатах работы ВОЗ. Программный бюджет на 2018-2019 гг. Среднесрочный обзор. [Электронный ресурс]. Режим доступа: <https://apps.who.int/iris/handle/10665/328790>.
- 17 Tussupova K. Access to Drinking Water and Sanitation in Rural Kazakhstan / K. Tussupova, P. Hjorth, R. Berndtsson // Int. J. Environ. Res. Public Health. — 2016. — Vol. 13. — P. 1115. <https://doi.org/10.3390/ijerph13111115>.
- 18 Об утверждении санитарных правил «Санитарно-эпидемиологические требования к осуществлению производственного контроля». Приказ Министра национальной экономики Республики Казахстан от 6 июня 2016 года. № 239 [Электронный ресурс]. Режим доступа: <https://adilet.zan.kz/rus/docs/V1600013896>.
- 19 Дусмагамбетов М.У. Санитарно-микробиологическая характеристика воды. Количественный и качественный состав: учеб. пос. / М.У. Дусмагамбетов, А.М. Дусмагамбетова. — Алматы: Newbook, 2018. — 136 с.
- 20 Сбойчаков В.Б. Микробиология, вирусология и иммунология: руководство к лабораторным занятиям: учеб. пос. / В.Б. Сбойчаков, М.М. Карапац. — М.: ГЭОТАР-Медиа, 2012. — 320 с.
- 21 МУК 10.05.045.03 Методы микробиологического контроля питьевой воды, 2003. Ответ Министра здравоохранения РК от 25 декабря 2019 года на вопрос от 11 ноября 2019 года. № 585115 [Электронный ресурс]. Режим доступа: https://online.zakon.kz/Document/?doc_id=37998310.
- 22 Зверев В.В. Микробиология: учеб. / В.В. Зверев, М.Н. Бойченко. — М.: ГЭОТАР-Медиа, 2012. — 608 с.
- 23 Ожередова Н.А. Санитарная микробиология: учеб. пос. / Н.А. Ожередова, А.Ф. Дмитриев, В.Ю. Морозов. — СПб.: Лань, 2020. — 176 с.
- 24 Сахарова О.В. Общая микробиология и общая санитарная микробиология: учеб. пос. / О.В. Сахарова, Т.Г. Сахарова. — СПб.: Лань, 2019. — 224 с.
- 25 Зверева В.В. Микробиология, вирусология: руководство к практическим занятиям: учеб. пос. / В.В. Зверева, М.Н. Бойченко. — М.: ГЭОТАР-Медиа, 2015. — 360 с.
- 26 Лабинская А.С. Руководство по медицинской микробиологии: учеб. пос. / А.С. Лабинская, Н.Н. Костюкова, С.М. Иванова. — М.: БИНОМ, 2012. — 1152 с.
- 27 Руководство по мембранной фильтрации Sartorius. Микробиологический контроль. Современные решения. [Электронный ресурс]. 2019. — Режим доступа: https://sartorius.nt-rt.ru/images/manuals/8_1_1_lab_filtrac_filtiry.pdf.
- 28 Шайзадина Г.Н. Предупредительный санитарный надзор: учеб. пос. / Г.Н. Шайзадина. — Алматы: Newbook, 2018. — 112 с.
- 29 Михалева Т.И. Санитарно-микробиологическое исследование объектов внешней среды и продуктов животного происхождения: учеб.-метод. пос. / Т.И. Михалева, Е.П. Евглевская, О.М. Швец, И.П. Арутюнова. — Курск: Курская ГСХА, 2013. — 44 с.

С.Б. Ахметова, И.А. Беляев, А.О. Омарова, Ж.Т. Амирханова

Жылдың әртүрлі мезгілінде Қарағанды қаласының Облыстық клиникалық ауруханасында судың және санитарлық пайдалану орындарының микробтық ластануын зерттеу

Қазіргі уақытта сумен жабдықтау сапасы және су пайдалану объектілерінің жағдайы адамдар мен жануарлардың денсаулығын, сондай-ақ халықтың өмір сүру сапасын қолдауда басты рөл атқарады. Мақаланың мақсаты — облыстың орталық және ең ауқымды медициналық мекемесі ретінде Қарағанды қаласындағы Облыстық клиникалық аурухананың құбыр суы мен санитарлық пайдалану орындарының микробтық ластану деңгейін жылдың әртүрлі мезгілінде бағалау. Зерттеудің нәтижелері бойынша келесідей қорытынды жасауға болады: зерттеу кезеңінде ағын суының зерттелген үлгілеріндегі көрсеткіштердің маусымдық өзгермелілігін байқауға болады. Орталық су құбырының суы жалпы колиформды және термотолерантты таяқша бактерияларының жүйелі түрде асып кетуімен сипатталады. Қарағанды қаласында нормативті көрсеткіштердің асқанына, жыл мезгілдеріне қарамастан сумен қамтамасыз ету сапасында үлкен тұрақтылық байқалады. Бұл суды тазарту сапасының төмендігін немесе сынама алу пункттеріндегі (Қарағанды қ. Облыстық клиникалық ауруханасы) су құбыры желісінің сапасына қатысты мәселелерді көрсетуі мүмкін. Сонымен қатар, көктем кезінде нәтижесі оң сынамалардың жоғары пайызын (шамамен 98 %) атап өткен жөн. Қыста нәтижесі оң сынамалардың пайызы аз және микробтық жүктемесі айтарлықтай төмен. Құбыр суының сапасы көктем мезгілінде төмендейді, сапасының нашарлауының ықтимал себебі — еріген және жаңбыр суының құбыр суы көзіне түсуі деп санаймыз. Су тазарту құрылыстарын пайдалану кезіндегі технологиялық шарттарының бұзылуы, тозған су құбыры желілеріндегі судың екінші ретті ластануы да қанағаттанарлықсыз нәтижелерге себеп болуы мүмкін. Қарағанды қ. Облыстық клиникалық ауруханасында алынған шайындылардың оң нәтижесінің жоғары пайызы байқалады, бұл облыстық маңызы бар ауруханада жүктеменің жоғарлығы, сондай-ақ микробқа қарсы дезинфекциялық құралдармен жақсы жабдықтаумен байланысты, бұл неғұрлым төзімді штамдарды іріктеп алуға әкеледі.

Кілт сөздер: құбыр суы, микробиология, жалпы колиформды бактериялар, термотолерантты колиформды бактериялар, шайынды.

С.Б. Ахметова, И.А. Беляев, А.О. Омарова, Ж.Т. Амирханова

Изучение микробного загрязнения воды и мест санитарного пользования в Областной клинической больнице г. Караганды в разные сезоны года

В современных условиях качество водоснабжения и состояние объектов водопользования играют ключевую роль в поддержании здоровья людей и животных, а также качества жизни населения. В связи с этим мы поставили целью нашего исследования — оценить уровень микробного загрязнения водопроводной воды и мест санитарного пользования в Областной клинической больнице (ОКБ) г. Караганды, как центрального и наиболее мощного медицинского учреждения области, в разные сезоны года. По результатам нашего исследования можно сделать следующие выводы: в период исследования прослеживается сезонная изменчивость показателей в исследуемых образцах водопроводной воды. Вода центрального водоснабжения характеризуется систематическими превышениями показателей, как общих колиформных, так и термотолерантных колиформных бактерий. В г. Караганде отмечается большая стабильность качества водоснабжения вне зависимости от сезонов, несмотря на превышение нормативных показателей. Можно говорить о либо низком качестве водоподготовки, либо о качественных проблемах на водопроводной сети в точках отбора (ОКБ г. Караганды). При этом стоит отметить высокий процент (почти 98 %) положительных проб в весенний период. В зимний период отмечается меньший процент положительных проб и значительно более низкая микробная нагрузка. Качество водопроводной воды снижается весной, мы считаем, что наиболее вероятная причина ухудшения качества воды — попадание в источник талых вод и стоков дождевой воды. Нарушения технологических условий эксплуатации сооружений водоподготовки, вторичное загрязнение воды в изношенных водоразводящих сетях также могут явиться причиной неудовлетворительных результатов. В Областной клинической больнице г. Караганды отмечается более высокий процент положительных смывов, что связывается с более высокой нагрузкой на стационар областного значения, а также более лучшим обеспечением антимикробными препаратами дезинфектантами, что приводит к избирательной селекции более устойчивых штаммов.

Ключевые слова: водопроводная вода, микробиология, общие колиформные бактерии, термотолерантные колиформные бактерии, смывы.

References

- 1 (2018). Posobie po uluchsheniiu vodosnabzheniia, sanitarii i gigieny v meditsinskikh uchrezhdeniakh. Vsemirnaia organizatsiia zdravookhraneniia. Litsenziia: CC BY-NC-SA 3.0 [Manual on improving water supply, sanitation and hygiene in medical institutions. License: CC BY-NC-SA 3.0]. Geneva: WHO. Retrieved from <https://apps.who.int/iris/bitstream/handle/10665/273032/9789244511695-rus.pdf> [in Russian].
- 2 (2019). Vodosnabzhenie, sanitariia i gigiena v meditsinskikh uchrezhdeniakh: Prakticheskie shagi po obespecheniiu vseobshchego dostupa k kachestvennoi pomoshchi. Litsenziia: CC BY-NC-SA 3.0 IGO [Water supply, sanitation and hygiene in medical institutions: Practical steps to ensure universal access to quality care. License: CC BY-NC-SA 3.0 IGO]. Zheneva: WHO. Retrieved from https://www.unwater.org/app/uploads/2020/04/Water-sanitation-and-hygiene-in-health-care-facilities-Practical-steps-to-achieve-universal-access-for-quality-care_RU.pdf [in Russian].
- 3 (2019). Vodosnabzhenie, sanitariia i gigiena v uchrezhdeniakh zdravookhraneniia. Semdesiat vtoraiia sessiia Vsemirnoi assamblei zdravookhraneniia. 72.7 Punkt 12.5 povestki dnia 28 maia 2019 goda [Water supply, sanitation and hygiene in healthcare institutions. Seventy-second session of the World Health Assembly. 72.7 Agenda item 12.5 May 28, 2019]. Retrieved from https://extranet.who.int/iris/restricted/bitstream/handle/10665/329293/A72_R7-ru.pdf?sequence=1&isAllowed=y [in Russian].
- 4 Abebe, L., Karon, A.J., Koltun, A.J., Cronk, R.D., Bain, R.E.S., & Bartram, J. (2018). Microbial contamination of non-household drinking water sources: a systematic review. *Journal of Water, Sanitation and Hygiene for Development*, 8 (3), 374–385.
- 5 Shields, K.F., Bain, R.E.S., Cronk, R., Wright, J.A., & Bartram, J. (2015). Association of supply type with fecal contamination of source water and household stored drinking water in developing countries: a bivariate meta-analysis. *Environ. Health Perspect.*, 123(12), 1222–1231. <https://doi.org/10.1289/ehp.1409002>
- 6 (2017). Tselevye pokazateli k Protokolu po problemam vody i zdorovia Konventsii po okhrane i ispolzovaniiu transgranichnykh vodotokov i mezhdunarodnykh ozer (Respublika Kazakhstan) [Targets for the Protocol on Water and Health Problems of the Convention on the Protection and Use of Transboundary Watercourses and International Lakes (Republic of Kazakhstan)]. Astana [in Russian].
- 7 (2015). Sanitarno-epidemiologicheskie trebovaniia k vodoistochnikam, mestam vodozabora dlia khoziaistvenno-pitevykh tselei, khoziaistvenno-pitevomu vodosnabzheniiu i mestam kulturno-bytovogo vodopolzovaniia i bezopasnosti vodnykh obektov. Prikaz Ministra natsionalnoi ekonomiki Respubliki Kazakhstan ot 16 marta 2015 goda No. 209 [Sanitary and epidemiological requirements for water sources, places of water intake for household and drinking purposes, household and drinking water supply and places of cultural and domestic water use and safety of water bodies. Order of the Minister of National Economy of the Republic of Kazakhstan of March 16, 2015 No. 209. Registered with the Ministry of Justice of the Republic of Kazakhstan on April 22, 2015 No. 10774]. Retrieved from https://online.zakon.kz/Document/?doc_id=36325897 [in Russian].
- 8 Toguzbayeva, K.K., Dzhambatyrova, A.E., Seiduanova, L.B., Niyazbekova, L.S., Kaldybai, A.U., Meirman, A.S., Toleu, E.T., & Zhunistaev, D.D. (2015). Gigienicheskaia otsenka kachestva selskogo vodosnabzheniia po rezul'tatam laboratornykh dannykh Enbekshikazakhskogo raiona [Hygienic assessment of quality of rural water supply by results of laboratory research of the Enbekshikazakh area]. *Vestnik Kazakhskogo natsionalnogo meditsinskogo universiteta — Bulletin of the Kazakh National Medical University*, 2; 634-637 [in Russian].
- 9 Toguzbayeva, K.K., Myrzahmetova, Sh.K., Niyazbekova, L.S., Orakbai, L.Zh., Zhunistayev, D.D., Seiduanova, L.B., Sailybekova, A.K., Smagulov, A.B., Sumenova, K.A., & Sabirova, G.R. (2014). Gigienicheskaia otsenka vliianiia kachestva khoziaistvenno-pitevogo vodosnabzheniia na zdorove selskogo naseleniia Almatinskoi oblasti [Hygienic assessment of quality water supply health of rural population of the Almaty region]. *Vestnik Kazakhskogo natsionalnogo meditsinskogo universiteta — Bulletin of the Kazakh National Medical University*, 3(3); 33–38 [in Russian].
- 10 Omarova, M.N., Totanov, Zh.S., Cherepanova, L.Yu., Glubokovskikh, L.K., Ereemeev, A.M. & Zholdaspaev, S.I. (2010). Sostoianie pitevogo vodosnabzheniia v selskoi mestnosti i ego vliianie na zdorove naseleniia [The state of drinking water supply in rural areas and its impact on public health]. Proceedings from Demographic situation in the Republic, problems and prospects: *Respublikanskaia nauchno-prakticheskaia konferentsiia (2010 goda) — Republican Scientific and Practical Conference*, 101,102. Karaganda [in Russian].
- 11 Nurbakyt, A.N., Absatarova, K.S., Buribaeva, Zh.K., Kazangapova, G.E., Sarsenbaev, E.Zh., & Davibaeva, B.R. (2010). Otsenka naseleniem sanitarno-gigienicheskikh uslovii v meditsinskikh organizatsiakh g. Almaty i Almatinskoi oblasti [Assessment by the population of sanitary and hygienic conditions in medical organizations of Almaty and Almaty region]. Retrieved from http://www.rusnauka.com/28_OINXXI_2010/Medecine/72649.doc.htm [in Russian].
- 12 Zhuravleva, T.A., & Grevtseva, N.A. (2016). Analiz finansirovaniia zdravookhraneniia v Rossii i ego otsenka dlia sokhraneniia zdorovia natsii [Analysis of healthcare financing in Russia and its assessment for the preservation of the health of the nation]. *Finansovaia zhizn — Financial Life*, 4; 75-80 [in Russian].
- 13 Zharkinov, E.Zh., Krasnikov, V.N., Totanov, Zh.S., Tashmetov, K.K., & Cherepanova, L.Yu. (2002). Sovremennye problemy gigieny sela i zadachi nauchnykh issledovaniu [Modern problems of rural hygiene and tasks of scientific research]. *Meditsina i ekologiia — Medicine and Ecology*, 2(22), 27–29 [in Russian].
- 14 (2017). Rukovodstvo po obespecheniiu kachestva pitevoi vody. 4-e izdanie. Litsenziia: CC BY-NC-SA 3.0 IGO. [Guidelines for drinking-water quality — 4th ed. License: CC BY-NC-SA 3.0 IGO.]. Zheneva: WHO. Retrieved from https://apps.who.int/iris/bitstream/handle/10665/44584/9789241548151_eng.pdf?sequence=1 [in Russian].
- 15 Bekturganov, Z., Tussupova, K., Berndtsson, R., Sharapatova, N., Aryngazin, K. & Zhanasova, M. (2016). Water related health problems in Central Asia. A review. *Water*, 8, 219. <https://doi.org/10.3390/w8060219>

- 16 (2018). Doklad o rezultatakh raboty VOZ. Programmnyi biudzhет na 2018–2019 gody. Srednesrochnyi obzor [WHO Performance Report Programme Budget for 2018-2019 Mid-term review]. Retrieved from <https://apps.who.int/iris/handle/10665/328790> [in Russian].
- 17 Tussupova, K., Hjorth, P. & Berndtsson, R. (2016). Access to Drinking Water and Sanitation in Rural Kazakhstan. *Int. J. Environ. Res. Public Health*, 13, 1115. <https://doi.org/10.3390/ijerph13111115>.
- 18 (2016). Ob utverzhdenii sanitarnykh pravil «Sanitarno-epidemiologicheskie trebovaniia k osushchestvleniiu proizvodstvennogo kontroliia». Prikaz Ministra natsionalnoi ekonomiki Respubliki Kazakhstan ot 6 iyunia 2016 goda No. 239 [On the approval of Sanitary rules “Sanitary and epidemiological requirements for the implementation of production control”. Order of the Minister of National Economy of the Republic of Kazakhstan of June 6, 2016 No. 239]. Retrieved from <https://adilet.zan.kz/rus/docs/V1600013896> [in Russian].
- 19 Dusmagambetov, M.U. & Dusmagambetova, A.M. (2018). Sanitarno-mikrobiologicheskaia kharakteristika vody. Kolichestvennyi i kachestvennyi sostav: uchebnoe posobie [Sanitary and microbiological characteristics of water. Quantitative and qualitative composition; study guide]. Almaty: Newbook [in Russian].
- 20 Sboichakov, V.B. & Karapats, M.M. (2012). Mikrobiologiiia, virusologiiia i immunologiiia: rukovodstvo k laboratornym zaniatiiam: uchebnoe posobie [Microbiology, Virology and Immunology; study guide]. Moscow: GEOTAR–Media [in Russian].
- 21 (2003). MUK 10.05.045.03 Metody mikrobiologicheskogo kontroliia pitevoi vody, 2003. Otvet Ministra zdravookhraneniia RK ot 25 dekabria 2019 goda na vopros ot 11 noiabria 2019 goda No. 585115 [MUK 10.05.045.03 Methods of microbiological control of drinking water, 2003. Response of the Minister of Health of the Republic of Kazakhstan dated December 25, 2019 to the question dated November 11, 2019 No. 585115]. Retrieved from https://online.zakon.kz/Document/?doc_id=37998310 [in Russian].
- 22 Zverev, V.V. & Boichenko, M.N. (2012). Mikrobiologiiia: uchebник [Microbiology; textbook]. Moscow: GEOTAR–Media [in Russian].
- 23 Ozheredova, N.A., Dmitriev, A.F. & Morozov, V.Yu. (2020). Sanitarnaia mikrobiologiiia: uchebnoe posobie [Sanitary microbiology: study guide]. Saint Petersburg: Lan [in Russian].
- 24 Sakharova, O.V. & Sakharova, T.G. (2019). Obshchaia mikrobiologiiia i obshchaia sanitarnaia mikrobiologiiia: uchebnoe posobie [General microbiology and general sanitary microbiology; study guide]. Saint-Petersburg: Lan [in Russian].
- 25 Zvereva, V.V. & Boichenko, M.N. (2015). Mikrobiologiiia, virusologiiia: rukovodstvo k prakticheskim zaniatiiam: uchebnoe posobie [Microbiology, virology: a guide to practical classes: study guide]. Moscow: GEOTAR–Media [in Russian].
- 26 Labinskaia, A.S., Kostiukova, N.N. & Ivanova, S.M. (2012). Rukovodstvo po meditsinskoii mikrobiologii: uchebnoe posobie [Guide to Medical Microbiology: study guide]. Moscow: BINOM [in Russian].
- 27 (2019). Rukovodstvo po membrannoii filtratsii Sartorius. Mikrobiologicheskii kontrol. Sovremennye resheniia. [Sartorius membrane filtration guidelines, Microbiological control Modern solutions]. Retrieved from https://sartorius.nt-rt.ru/images/manuals/8_1_1_lab_filtrac_filtry.pdf [in Russian].
- 28 Shaizadina, G.N. (2018). Predupreditelnyi sanitarnyi nadzor: uchebnoe posobie [Preventive sanitary supervision: study guide]. Almaty: Newbook [in Russian].
- 29 Mikhaleva, T.I., Evglevskaia, E.P., Shvets, O.M. & Arutiunova, I.P. (2013). Sanitarno-mikrobiologicheskoe issledovanie obektov vneshnei sredy i produktov zhivotnogo proiskhozhdeniia: uchebno-metodicheskoe posobie [Sanitary and microbiological examination of environmental objects and animal products; study guide]. Kursk: Kurskaia gosudarstvennaia selskokhoziaistvennaia akademiia [in Russian].